

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1615:178

Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Bosch Security Systems, 130 Perinton Pkwy, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 223-4060 FAX (585) 421-4263

DESIGN: Models D603, D604, and D605 heat detectors. Model D604 is a 135° fixed temperature detector, Model D603 is a 135° fixed temperature with 15° rate-of-rise detector, and Model D605 is a 190° fixed temperature detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8.5-33 VDC
D604: 135° fixed temperature
D603: 135° fixed temperature with 15° rate-of-rise
D605: 190° fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detectors for use with listee's separately listed compatible fire alarm control units and listed bases (CSFM Listing No. 7300-1615:133 and 7300-1615:109). Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 7270-0801:210

01-06-2005KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 3, 2006**

*Listing Expires **June 30, 2007***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**